



NOTES:

- 1) VALVE BOX ASSEMBLY SHALL NOT REST ON BLOW-OFF ASSEMBLY.
- 2) USE APPROVED JOINT COMPOUND ON ALL THREADED CONNECTIONS.
- 3) ALL NIPPLES, ELBOWS, AND PIPE SHALL BE BRASS.
- 4) PLACE IN-LINE VALVE IMMEDIATELY PRIOR TO LAST PIPE LENGTH.
- 5) IN TRAFFIC AREAS, METER BOX MUST BE EQUIPPED WITH AN APPROVED TRAFFIC RATED LID.

CITY OF CORVALLIS

ENGINEERING DIVISION

DEAD END MAIN &
BLOW-OFF SETTING

DATE: JULY, 2005

SCALE: NONE

STANDARD DETAIL No.

APPROVED:

304